



Bureau of Environmental Health
 8930 Stanford Blvd | Columbia, MD 21045
 410.313.2640 - Voice/Relay
 410.313.2648 - Fax
 1.866.313.6300 - Toll Free

Maura J. Rossman, M.D., Health Officer

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: Heil Plumbing Telephone #: 410-799-7727
 Address: 8177 Mission Rd
Jessup MD

Must circle one: Licensed Plumber / Licensed Well Driller / Licensed Well Pump Installer

License # and name of individual responsible for the field installation:
 Name (Print): Edward Heil License# 20020006428

*A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.

Name of Property Owner: Marina Furti Telephone #: 443-896-4865
 Subdivision: 3003 Lot #: 1 Well Tag #: HO-unk-unk
 Site Address: 6210 Woodleigh Dr
Columbia MD 21044

Submersible Pump Data

Make: unk
 Model #: unk
 Pump Capacity: unk
 Well Yield: unk
 Depth of well encountered at time of pump installation: unk (feet)

Pitless Adapter

Make: Boshart +
 Model#: P-100-SS
 GPM Depth: unk (36" min)
 GPM NSF/WSC approved: unk

Well Cap and Electric Conduit

Two piece watertight cap:
 Screened, vented well cap:
 Cap secured to casing:
 Conduit min 18" B.G.:
 Conduit secured to well cap:

"unk" =
 unknown
 existing
 materials

If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4

Must circle one: Torque arrestors / Cable guards / Other acceptable method used

Safety rope, if used, attached to brass rope adapter or other acceptable method inside of well casing unk

Piping to house

Type: HDPE
 PSI: 200 (160 psi min)
 Depth of supply line: 48" (36" min)

House Connection

PVC sleeve to undisturbed soil at wall penetration:
 Length of sleeve (5' minimum from foundation):
 Sleeve sealed properly:

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

[Signature]

Signature of company representative responsible for installation

4/1/24

date

For Health Department Use Only - Not to be completed by Installer

Date Insp. Requested: 3/27/2024 Date Insp. Approved: 4/1/2024 Inspector: SP
 Inspection Data: Pitless adapter watertight & water supply line at least 36" below grade
 Two piece cap installed and attached to casing securely
 Elec. conduit extends at least 18" below grade/attached to cap properly
 Safety rope not outside of well cap/casing
 Correct well tag attached properly and casing 8" above finished grade
 Water supply line sleeved adequately at house connection
 Adequate grout observed below pitless adapter

4/1/2024..
received pic of
extended sleeve coming
out of house, sleeve
5' from foundation

(Revised form 10/24/2018)



4/1/2024 - Received pic of extended sleeve coming out of house. sleeve 5' from foundation. 