

A/P _____

(7/11/07 Done @ time of layout.)

8"

Dark Brown
Lm. organic
yellowish Brown
heavy Si lm
subangular Blocky
Friable when wet
Very Dense.

3-4'

Saprolite of
lamm or si lm
texture. friable.
Coarse in some
areas. Highly
micaceous.
Structure from rock
30-40% rock.

11'

Ex
House.

189'

SDA

A

25'

75'

* Per Hole dug to confirm system design.

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2nd INCH	P/F/H
7/11/07	A	3.5' / 11v		1/4" movement			F
		5.3' / 11v	11:15	11:22	11:43	21	P
		* Rate's		got faster	Deeper *		

REMARKS Poured water @ bottom of hole. very Fast!

SANITARIAN (Kw) BACKHOE Kerry Myre OTHERS _____

TEST HOLES USED IN SDA _____ AVG. PERC TIME _____ SQ. FT/BR _____

TRENCH WIDTH _____ INLET DEPTH _____ MAX. BOT DEPTH _____ EFFECTIVE SAW _____