

APPLICATION

PERCOLATION TESTING

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
P.O. BOX 476 ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 461-9933

A 40055

P _____

DISTRICT 4TH

DATE 9-8-87

*10/20/88
perc OK'd pending
approved plan
@*

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Kennard Warfield Jr

ADDRESS 14663 Tridelphia Rd Glenely 21737 PHONE 442-2337

PROSPECTIVE BUYER N/A

ADDRESS _____ PHONE _____

PROPERTY LOCATION:

SUBDIVISION White Property Whitewood EST. LOT NO. 3

ROAD AND DESCRIPTION South side of Balto National Pike (Rt 144) north
side of Hardy Rd 17413 - WYR Dogwood Ct.

TAX MAP 7 PARCEL # 1

SIZE OF LOT 3 ± acres TYPE BLDG. SFD
(SINGLE FAMILY DWELLING OR COMMERCIAL)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE. I FULLY UNDERSTAND THE

FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES. I ALSO AGREE TO COMPLY

WITH ALL M.O.S.H.A. REQUIREMENTS IN TESTING THIS LOT. Mal D. Rein
(SIGNATURE OF APPLICANT)

APPROVED BY Fickus Abel FOR Deep trenches DATE 8-12-88

REJECTED BY _____ FOR _____ DATE _____

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING for field located holes & subst plan
that lines need adjusting

PERMIT SIGNED
AND RETURNED 5-15-89

BP-25933

THIS IS NOT A PERMIT

STAKED

412



P.L. Stokan

$$\bar{X} = 44.12$$

TOLET

MAY 1964

180 ~~1~~ 180RM

4

70 brown/orang
 77 yellow
 patches
 - clay/silty
 clay mix
 3'
 70 to orange
 87 tan
 silty loam
 w/ 10-15%
 small frogs
 scattered
 4' 1"

 12' D

②

brown
clay 4'
brown to
orange
clay till
4 1/2 - 5'
to orange
iron silty
lean
w/ 10-15%
small
hard
weathered
frag

[illegible]

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE

SOIL PROFILE

patches of
yellow, tan
brown
sandy clay
rock 2 1/2'
to nearly
orange w/
tan + white
patches
small
weathered
frag
10 1/2' 1 1/2'

12

REC
LOT
WAV

②

brown/orange
gitty clay
silt mix
3 1/2
to nearly
orange to
silty loam
25% small
weathered
frag.

128

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
10/30/57	①	2½'S	1155	1157	1157	1200	3min
		7' m	1155	1156	1156	1158	2min
		12' D	bottom (see profile)				
	②	VISUAL ONLY	good soils 3½' ↓				
		12' D	bottom (see profile)				
	③	4½'S	1203	1207	1207	1211	4min
		12½ D	bottom (see profile)				
	④	3½'S	1207	1210	1210	1217	7min
		12' D	bottom (see profile)				

perc field adjusted uphill = 50 to stay out of $\frac{1}{12.0}$
 marginal soils, probably reserve for line
 adjustments (line between 2+3) for house/well

REMARKS

TYPE OF SOIL

TESTED BY

B Nyhan

ALSO PRESENT

Alan R. Pope

EH-12-1079