

## Williams, Jeffrey

---

**From:** Williams, Jeffrey  
**Sent:** Monday, April 7, 2025 8:55 AM  
**To:** Julia Yuan  
**Subject:** RE: Sewer connection grant

Hello. Unfortunately the inspector did not see anything that would indicate a system that is in failure or not functioning properly during his site visit. The liquid levels in the tank and drywell were at operational levels and the trench was probed with no evidence of clogging or failure.

Based on these findings, we cannot claim the system to be failing for purposes of grant eligibility. You are welcome to make a public connection at any time without grant assistance, or you can continue to use your septic system and contact us again if you see any evidence of failure. Thanks

Jeff Williams  
Deputy Director  
Bureau of Environmental Health  
Howard County Health Dept.  
8930 Stanford Blvd. Columbia, MD 21045  
410-313-4261  
[www.hchealth.org](http://www.hchealth.org)

DISCLAIMER: This e-mail is intended only for the individual to whom it is addressed. It may be used only in accordance with applicable laws. If you are not the intended recipient, you are strictly prohibited from reading, disseminating, distributing, or copying this message. If you received this e-mail by mistake, please notify the sender and destroy this e-mail

**From:** Williams, Jeffrey  
**Sent:** Monday, March 24, 2025 9:00 AM  
**To:** Julia Yuan <[jooya11@yahoo.com](mailto:jooya11@yahoo.com)>  
**Subject:** RE: Sewer connection grant

I can have an inspector reach out to you to schedule a site visit. Did the pumper indicate anything wrong when they pumped it out?

**From:** Julia Yuan <[jooya11@yahoo.com](mailto:jooya11@yahoo.com)>  
**Sent:** Friday, March 21, 2025 8:53 PM  
**To:** Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)>  
**Subject:** Re: Sewer connection grant

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Hello,

We had our tank pumped last fall but it's as old as the house. Our house was built in 1969. I was thinking that because our septic is now 55+ years old that it's gotta go soon. Is it possible to get a visual inspection?

Thank you,  
Julia Yuan

On Thursday, February 20, 2025 at 08:33:36 AM EST, Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)> wrote:

Hello. We don't have heavy equipment to dig up and inspect a septic system, we can only do a visual inspection of the yard where the system is located. If you are not noticing any issues with your plumbing or your system, such as backups or sewage ponding on the ground, it is likely that your system is functioning properly. They can last many decades in decent soil and properly cared for. Have you had your tank pumped anytime recently or are you seeing any problems with your plumbing or in your yard?

---

**From:** Julia Yuan <[jooya11@yahoo.com](mailto:jooya11@yahoo.com)>  
**Sent:** Saturday, February 15, 2025 2:29 PM  
**To:** Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)>  
**Subject:** Re: Sewer connection grant

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Hello Mr Williams, would it possible to see if there is something potentially wrong with our septic system?it has been fixed once in the last 10 years and not sure how li g that fix would last.

Thank you,  
Julia Yuan

Sent from Yahoo Mail for iPhone

On Tuesday, January 14, 2025, 3:50 PM, Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)> wrote:

Hello. Sorry for the delayed response. The grant can help cover the cost of connecting to public sewer if the health department has verified a failing condition with the existing septic system. Is there anything going wrong with your system?

Jeff Williams

Deputy Director

Bureau of Environmental Health

Howard County Health Dept.

8930 Stanford Blvd. Columbia, MD 21045

410-313-4261

[www.hchealth.org](http://www.hchealth.org)

DISCLAIMER: This e-mail is intended only for the individual to whom it is addressed. It may be used only in accordance with applicable laws. If you are not the intended recipient, you are strictly prohibited from reading, disseminating, distributing, or copying this message. If you received this e-mail by mistake, please notify the sender and destroy this e-mail

---

**From:** Julia Yuan <[jooya11@yahoo.com](mailto:jooya11@yahoo.com)>  
**Sent:** Thursday, January 2, 2025 1:59 PM  
**To:** Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)>  
**Subject:** Sewer connection grant

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Dear Mr. Williams,

I am writing to gather information on the county's sewer connection grant program. My neighbor just recently utilized the program to help fund their conversion from septic and connect to the city sewer. We are looking to see if this is something we can also do as we are currently on septic. If you can provide me with information on this program, I'd greatly appreciate it. My house is at 10226 Dolliter Court, EC 21042.

Thank you,  
Julia Yuan



## Williams, Jeffrey

---

**From:** Julia Yuan <jooya11@yahoo.com>  
**Sent:** Friday, March 21, 2025 8:53 PM  
**To:** Williams, Jeffrey  
**Subject:** Re: Sewer connection grant

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Hello,

We had our tank pumped last fall but it's as old as the house. Our house was built in 1969. I was thinking that because our septic is now 55+ years old that it's gotta go soon. Is it possible to get a visual inspection?

Thank you,  
Julia Yuan

On Thursday, February 20, 2025 at 08:33:36 AM EST, Williams, Jeffrey <jewilliams@howardcountymd.gov> wrote:

Hello. We don't have heavy equipment to dig up and inspect a septic system, we can only do a visual inspection of the yard where the system is located. If you are not noticing any issues with your plumbing or your system, such as backups or sewage ponding on the ground, it is likely that your system is functioning properly. They can last many decades in decent soil and properly cared for. Have you had your tank pumped anytime recently or are you seeing any problems with your plumbing or in your yard?

---

**From:** Julia Yuan <jooya11@yahoo.com>  
**Sent:** Saturday, February 15, 2025 2:29 PM  
**To:** Williams, Jeffrey <jewilliams@howardcountymd.gov>  
**Subject:** Re: Sewer connection grant

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Hello Mr Williams, would it possible to see if there is something potentially wrong with our septic system?it has been fixed once in the last 10 years and not sure how long that fix would last.

Thank you,  
Julia Yuan

Sent from Yahoo Mail for iPhone

On Tuesday, January 14, 2025, 3:50 PM, Williams, Jeffrey <jewilliams@howardcountymd.gov> wrote:

Hello. Sorry for the delayed response. The grant can help cover the cost of connecting to public sewer if the health department has verified a failing condition with the existing septic system. Is there anything going wrong with your system?

Jeff Williams

Deputy Director

Bureau of Environmental Health

Howard County Health Dept.

8930 Stanford Blvd. Columbia, MD 21045

410-313-4261

[www.hchealth.org](http://www.hchealth.org)

DISCLAIMER: This e-mail is intended only for the individual to whom it is addressed. It may be used only in accordance with applicable laws. If you are not the intended recipient, you are strictly prohibited from reading, disseminating, distributing, or copying this message. If you received this e-mail by mistake, please notify the sender and destroy this e-mail

---

**From:** Julia Yuan <jooya11@yahoo.com>  
**Sent:** Thursday, January 2, 2025 1:59 PM  
**To:** Williams, Jeffrey <jewilliams@howardcountymd.gov>  
**Subject:** Sewer connection grant

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Dear Mr. Williams,

I am writing to gather information on the county's sewer connection grant program. My neighbor just recently utilized the program to help fund their conversion from septic and connect to the city sewer. We are looking to see if this is something we can also do as we are currently on septic. If you can provide me with information on this program, I'd greatly appreciate it. My house is at 10226 Dolliter Court, EC 21042.

Thank you,  
Julia Yuan

1/22/76  
file OK WWB

# PERMIT

P 22744  
A \_\_\_\_\_

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

## INDEXED

DISTRICT 2

DATE 1/21/76

Jack Fyock IS PERMITTED TO INSTALL ALTER

ADDRESS Ten Oaks Road, Dayton, Maryland PHONE 286-2939

A SEWAGE DISPOSAL SYSTEM LOCATED AT \_\_\_\_\_

SUBDIVISION Allenford ROAD 10226 Doliter Court LOT 6, Blk. B, Sec. 1

PROPERTY OWNER Douglas Lichter Charles K. Clopin

ADDRESS \_\_\_\_\_

### SPECIFICATIONS

DRAIN FIELD \_\_\_\_\_ DEPTH \_\_\_\_\_ FEET, BOTTOM AREA \_\_\_\_\_ SQ. FT.

SEEPAGE PITS \_\_\_\_\_ ABSORBENT SIDE-WALL AREA \_\_\_\_\_ SQ. FT.

SEPTIC TANK CAPACITY \_\_\_\_\_ GALLONS

FOR GARBAGE GRINDER, INCREASE DISPOSAL AREA 22% & TANK CAPACITY 50%.

OTHER REPAIR - Call for inspection before ground is opened up so Sanitarian can

recommend repair system.

Hard ground starts @ 5 1/2' as per J. Fyock


PLANS APPROVED BY P. F. Wine DATE 1/21/76

FILL SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

REC'D. PERMIT SIGNATURE  
AND RETURNED 3/29/76  
Serial # 17326 - Pm

X  
7  
22744



10  
46  
4

PERMIT CARD

SEPTIC TANK, LEVEL existing CLEANOUTS existing

DISTRIBUTION BOX, LEVEL \_\_\_\_\_

TILE FIELD, DEPTH \_\_\_\_\_ FT. TRENCH WIDTH 2 1/2 FT.

GRAVEL DEPTH ~8 FT. TOTAL LENGTH 58 FT.

NUMBER OF TRENCHES 1 TOTAL BOTTOM AREA 464 <sup>SIDEWALL</sup> 406 <sub>EFF " "</sub> (below 5 1/2' clay barrier)

12-13'  
gravel to top  
4 1/2'

SEEPAGE PITS, INSIDE DIAMETER \_\_\_\_\_ FT. DEPTH BELOW INLET \_\_\_\_\_ FT.

ABSORBENT AREA \_\_\_\_\_ SQ. FT.

REMARKS 1/22/76 Ditch was 12 to 13 feet. I agree with the job which was done.

Mr. Richard K. Clapp

Ditch complete when I arrived @ 12:15. Owner signed above.

Orangeburg pipe used for ST (same as reg.)

DATE SYSTEM APPROVED 1/22/76 INSPECTOR William Th. Zapp

