

6/7/64

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

INDEXED

ELLICOTT CITY

DISTRICT 5

DATE 6/3/64

P 08542

A 08217

Tattrie & Lay Const. Co. IS PERMITTED TO INSTALL X ALTER

ADDRESS Simpsonville, Maryland PHONE AT 6-2241

A SEWAGE DISPOSAL SYSTEM LOCATED AT _____

SUBDIVISION _____ ROAD _____ LOT _____

PROPERTY OWNER Irene F. Smith

ADDRESS 2929 Connecticut Ave., Washington, D. C. Adams 4-7594

SPECIFICATIONS 3 bedrooms

DRAIN FIELD _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

SEEPAGE PITS _____ ABSORBENT SIDE-WALL AREA _____ SQ. FT.

SEPTIC TANK CAPACITY 750 GALLONS

FOR GARBAGE GRINDER, INCREASE DISPOSAL AREA 22% & TANK CAPACITY 50%.

OTHER Dry well - 300 sq. ft. absorbent side wall area below inlet pipe.
Locate dry well 235 ft. from front lot line and 58 ft. from
left side line as lot is seen when facing it from Lime Kiln Road.

PLANS APPROVED BY Ronald Fletcher DATE 4/2/64

FILL SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

08217

APPLICATION

SEWAGE DISPOSAL TESTING

A-08217

P

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 5

DATE 3/30/64

Sectric tank - 750 gal
Drywell - 300 sq. ft absorbent sidewall area
below inlet pipe

Locate drywell 235 ft. from front lot line and
58 ft. from left side line as left is seen
when facing it from Lime Kiln Rd.

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Irene F. Smith

ADDRESS 2929 Connecticut Ave., Washington, D. C. PHONE Adams 4-7594

PROPERTY LOCATION:

SUBDIVISION LOT NO.

ROAD AND DESCRIPTION Rt. 216 - turn left on Lime Kiln Rd.

OCCUPANT PHONE

PERSON TO CONSTRUCT SYSTEM

ADDRESS PHONE

SIZE OF LOT 6 acres plus TYPE BLDG. 3
NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE

SIGNATURE OF APPLICANT Roy R. G. Lattner, for Lattner & Leung Brothers Inc.

APPROVED BY Roy R. G. Lattner FOR DATE 4/2/64
(KIND OF SYSTEM)

REJECTED BY FOR DATE
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS DATE

REASONS FOR REJECTION OR HOLDING

THIS IS NOT A PERMIT

