

4/25/89 10:27
#4.00 P.M.

File 03-313/166

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

BUREAU OF ENVIRONMENTAL HEALTH

461-9933

P 43965

A 38710

DISTRICT 3rd

DATE 4/13/89

DATE SYSTEM APPROVED 4/25/89

INSPECTOR C.B. D.

INDEXED

C. C. Cissel

IS PERMITTED TO INSTALL ☒ ALTER

ADDRESS 14079 Brighton Dam Road, Clarksville, Maryland PHONE 854-2006

SUBDIVISION Triadelphia Ridge Estates ROAD 13060 Triadelphia Rd LOT 13

PROPERTY OWNER Bob Rao LARRY MATZ

ADDRESS

IF GARBAGE GRINDER IS USED INCREASE SEPTIC TANK CAPACITY BY 50% AND ABSORPTION AREA BY 22%.

GARBAGE GRINDER? YES NO ☒

SEPTIC TANK CAPACITY 1250 GALLONS NUMBER OF BEDROOMS 4

TRENCHES - 170 sq. ft. per bedroom. Trench to be 2 feet wide. Inlet 4 1/2 feet below original grade. Bottom maximum depth 8 1/2 feet below original grade. Effective area begins at 4 1/2 feet below original grade. 4 feet of stone below distribution pipe.

LOCATION - Start the first trench 160 feet up the left (500') lot line and 70 feet from the left lot line as seen when facing the property from Triadelphia Road. Run trench(s) along contour toward right side of lot.

NOTE - No trench to exceed 100 feet in length. Provide 6" - 8" diameter cleanout and cap to grade or above on septic tank. ok/cw

Manhole type needed - ok
4/25 c.o. @ S. Tahl C.B.D.

PLANS APPROVED BY C. Williams

DATE 7/14/88

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCHES ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCHES

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH.

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA OR PVC OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET, MANHOLE TO GRADE REQUIRED


NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT

*CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEMS.

BLDG PERMITS DIVISION
AND RETURNED 5/4/2000
BO 6123976
INGROUND POOL

A 38710



← TRIADELPHIA ROAD →

APPLICATION

PERCOLATION TESTING

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
P.O. BOX 476 ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 461-9933

A 38710

P

DISTRICT 3

DATE 1/21/87

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER KOTTAPALLI B RAO

ADDRESS 6570 Rt 32, Clarksville PHONE 854-0809

PROSPECTIVE BUYER

ADDRESS PHONE

PROPERTY LOCATION:

SUBDIVISION Tridelphia Ridge Estate LOT NO. 5 (13)

ROAD AND DESCRIPTION 13060 Tridelphia Road

TAX MAP 22 PARCEL # 17

SIZE OF LOT 3A TYPE BLDG. Single Family Dwelling
(SINGLE FAMILY DWELLING OR COMMERCIAL)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE. I FULLY UNDERSTAND THE FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES. I ALSO AGREE TO COMPLY WITH ALL M.O.S.H.A. REQUIREMENTS IN TESTING THIS LOT.

(SIGNATURE OF APPLICANT)

APPROVED BY S. Abel FOR Deep trenches DATE 7-26-88

REJECTED BY FOR DATE

HOLD PENDING FURTHER TESTS DATE

REASONS FOR REJECTION OR HOLDING 2-25-87 Per satisfactory - hold for subdivision plat.

S. Abel

BLDG. PERMIT SIGNED
AND RETURNED 7-26-88

BP20274

THIS IS NOT A PERMIT

574	555.7
575	555.7
576	555.7
577	555.7
578	555.7
579	555.7
580	555.7
581	555.7
582	555.7
583	555.7
584	555.7
585	555.7
586	555.7
587	555.7
588	555.7
589	555.7
590	555.7
591	555.7
592	555.7
593	555.7
594	555.7
595	555.7
596	555.7
597	555.7
598	555.7
599	555.7
600	555.7

RUDOLPH
NOTHURFT

L 1155 F. 120

1954 F.356

CURVE DATA					
PIVOT	Δ	ARC	TAN	CHORD BEARING	CHORD
5.00	145° 11' 25"	21.03	11.15	S 41° 05' 21" E	20.21
0.00	115° 11' 25"	21.07	22.75	S 67° 50' 00" E	55.55
0.00	145° 11' 25"	21.05	11.15	N 01° 55' 07" E	20.21

LOT 1
BURGESS PROP

॥ ५५ ॥

TRIA DEL FIA
RIDGE
ESTATES

FILES 107

52370

TEYNARD
DRIVE
(50' R/W)

0.2776 OR 0.1905 ACRES OF
LAND DEDICATION TO HOWARD
COUNTY, MARYLAND FOR THE
PURPOSE OF A PUBLIC ROAD.

LOT 10

5524 ON
5529 AC.

95,000

LOT 14

147,575 000

PARTY 600000
50%

KINGSTON
SECTION 2
PAGE 2

92,900

LOT 11

٥٠٤، ٥٠٥

89,900

LOT 12


174. 8-30-20

89,909.48

LOT 13

138.4-4 = 0

SECRET
-33- Page




OWNER'S CERTIFICATE


KOTTAPALLI B. RAO, OWNER OF THE PROPERTY SHOWN AND DESCRIBED HEREON HEREBY ACCEPT THIS PLAN OF RESUBDIVISION, AND IN CONSIDERATION OF THE APPROVAL OF THIS FINAL MAP BY THE OFFICE OF PLANNING AND ZONING, ESTABLISH THE MINIMUM BUILDING RESTRICTION LINES AND GRANT UNTO HOWARD COUNTY, MARYLAND, ITS SUCCESSORS AND ASSIGNS, (1) THE RIGHT TO LAY CONSTRUCT AND MAINTAIN SEWERS, DRAINS, WATER PIPES AND OTHER MUNICIPAL UTILITIES AND SERVICES, IN AND UNDER ALL ROAD AND STREET RIGHT-OF-WAYS AND THE SPECIFIC EASEMENT AREAS SHOWN HEREON; (2) THE RIGHT TO REQUIRE DEDICATION FOR PUBLIC USE THE BEDS OF THE STREET AND/OR ROAD AND FLOOD PLAIN AND OPEN SPACE WHERE APPLICABLE, AND FOR GOOD AND OTHER VALUABLE CONSIDERATION, HEREBY GRANT THE RIGHT AND OPTION TO HOWARD COUNTY TO ACQUIRE THE FEE SIMPLE TITLE TO THE BEDS OF THE STREETS AND/OR ROADS AND FLOOD PLAIN, STORM DRAINAGE FACILITIES AND OPEN SPACE WHERE APPLICABLE. (3) THE RIGHT TO REQUIRE DEDICATION OF WATER AND AS SHOWN HEREON.

SURVEYOR'S CERTIFICATE

I HEREBY CERTIFY THAT THE SURVEY HEREON IS CORRECT, THAT IT IS THE LAND CONVEYED BY ERIC S. SOLOMON TO KOTTAPALLI B. RAO BY DEED DATED 29, 1986 AND RECORDED IN LAND RECORDS AMONG THE LAND RECORDED IN THE SUBDIVISION BY HOWARD COUNTY IN ACCORDANCE WITH THE ANTI-SPECULATION ACT.



KINGSTON
SECTION 2
P.D.22 P.42




GENERAL NOTES

1. PROPERTY ZONED: R, PER 82-85 COMPREHENSIVE ZONING PLAN.
2. COORDINATES BASED ON MARYLAND STATE PLANE SYSTEM.
3. B.R.L. - BUILDING RESTRICTION LINE
4. THIS AREA DESIGNATES A PRIVATE SEWAGE EASEMENT OF ~~APPROXIMATE~~ 10,000 ± AS REQUIRED BY MARYLAND STATE DEPARTMENT OF HEALTH AND MENTAL HYGIENE FOR INDIVIDUAL SEWAGE DISPOSAL IMPROVEMENTS OF ANY NATURE IN THIS AREA IS PROHIBITED UNTIL PUBLIC SEWAGE IS AVAILABLE AND SERVICING ANY RESIDENTIAL STRUCTURE CONSTRUCTED ON THESE BUILDING SITES. THIS

E80850
N523,500

AREA TABULATION	
TOTAL No. OF LOTS TO BE RECORDED	5
TOTAL AREA OF LOTS TO BE RECORDED	103,487 ± OR 16.1428 ACRES
TOTAL AREA OF ROADWAY TO BE RECORDED	8,209 ± OR 0.1705 ACRES
TOTAL AREA OF SUBDIVISION TO BE RECORDED	111,786 ± OR 16.3404 ACRES



NOTE: VEHICULAR INGRESS & EGRESS RESTRICTED ALONG THIS PORTION OF TRIADELPHIA ROAD

APPROVED: FOR HOWARD COUNTY HEALTH DEPARTMENT FOR PRIVATE WATER AND PRIVATE SEWAGE SYSTEM.
James M. Boyd M.D. *5.23.88*
HOWARD COUNTY HEALTH OFFICER # DATE

APPROVED: HOWARD COUNTY OFFICE OF PLANNING AND ZONING.
[Signature] *6.3.88*
DIRECTOR DATE

APPROVED: FOR STORM DRAINAGE SYSTEMS & PUBLIC ROAD. HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS
James M. Boyd *5/31/88*
DIRECTOR DATE


OWNER'S CERTIFICATION

I KOTTAPALLI B. RAO, OWNER OF THE PROPERTY SHOWN AND ADOPT THIS PLAN OF RESUBDIVISION, AND IN CONSIDERATION OF THE A PLAT BY THE OFFICE OF PLANNING AND ZONING, ESTABLISH THE M TION LINES AND GRANT UNTO HOWARD COUNTY, MARYLAND, ITS SUCCE THE RIGHT TO LAY CONSTRUCT AND MAINTAIN SEWERS, DRAINS, WAT IFAL UTILITIES AND SERVICES, IN AND UNDER ALL ROAD AND STREET RIGH IFIC EASEMENT AREAS SHOWN HEREON; (2) THE RIGHT TO REQUIRE DEDICATIO OF THE STREET AND/OR ROAD AND FLOOD PLAIN AND OPEN SPACE WHERE A AND OTHER VALUABLE CONSIDERATION, HEREBY GRANT THE RIGHT AND OPTION ACQUIRE THE FEE SIMPLE TITLE TO THE BEDS OF THE STREETS AND/OR ROAD DRAINAGE FACILITIES AND OPEN SPACE, WHERE APPLICABLE; (3) THE RIGHT TO R WAYS AND DRAINAGE EASEMENTS FOR SPECIFIC PURPOSE OF THEIR CONSTRUCTION, R (4) THAT NO BUILDING OR SIMILAR STRUCTURE OF ANY KIND SHALL BE ERECTED EASEMENTS AND RIGHT-OF-WAYS.

Kottapalli B. Rao
KOTTAPALLI B. RAO

WITNESS MY HAND THIS
[Signature]
WITNESS

SITE PLAN
LOT 13, TRIDELPHIA RIDGE ESTATES
WEST FRIENDSHIP (3RD) DISTRICT
HOWARD COUNTY, MARYLAND
SCALE 1" = 100' JULY, 1988



Note
R.M.
4/25
W.P.I
No line
No etc
Nath
C.B.R.

MANHOLE TO GRADE
REQUIRED
SA

7/26/88

elevation on
SAB

TRIDELPHIA ROAD

BDDG. PERMIT SIGNED
AND RETURNED 7-26-88

BP20271

S. Allen

I CERTIFY TO THE BEST OF
MY KNOWLEDGE AND BELIEF
THAT THE PLAN SHOWN HEREON
IS CORRECT.

W. Allen Brown 7/20/88
MD. P.L.S. # 299

THE BOUNDARY INFORMATION
SHOWN HEREON IS BASED UPON
DEED(S) AND/OR PLATS OF RECORD
AND DOES NOT REFLECT A
BOUNDARY SURVEY.

Al Brown Surveys Inc.

7305 MINK HOLLOW ROAD
HIGHLAND, MARYLAND 20777
RES. 301-854-0913

B 1	1293	SEQUENCE NO. (DP USE ONLY)	STATE OF MARYLAND PERMIT TO DRILL WELL please print or type	STATE PERMIT NUMBER HO-38-0037 fill in this form completely
Date Received (APA) 062188 OWNER INFORMATION RAO Last Name BOB First Name 6570 K F 3 R Street or RFD CLARKESVILLE Town MD State 21027 Zip				
DRILLER INFORMATION Joseph L. Mayne Driller's Name 238 License No. 80 Joseph L. Mayne - Well Drilling Firm Name 5512 Ridge Rd. Mt. Airy 21771 Address Joseph L. Mayne Signature 6/27/88 Date				
LOCATION OF WELL HOWARD COUNTY FRITH LINDA RIDGE L.S. SUBDIVISION SECTION 44 LOT 3 CLARKESVILLE NEAREST TOWN MILES FROM TOWN (enter 0 if in town) 2 MI				
WELL INFORMATION APPROX. PUMPING RATE (GAL. PER MIN.) 5 AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 500				
USE FOR WATER (CIRCLE APPROPRIATE BOX) ☒ HOME (SINGLE OR DOUBLE HOUSEHOLD UNIT ONLY) ☐ FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) ☐ INDUSTRIAL, COMMERCIAL, STATE AND FEDERAL GOV. OTHER (REQUIRES APPROPRIATION PERMIT) ☐ PUBLIC OR PRIVATE WATER COMPANY (REQUIRES APPROPRIATION PERMIT AND STATE HEALTH DEPARTMENT APPROVAL) ☐ TEST, OBSERVATION, MONITORING (MAY REQUIRE APPROPRIATION PERMIT)				
NOT TO BE FILLED IN BY DRILLER HEALTH DEPARTMENT APPROVAL HOWARD COUNTY NAME A 38700 COUNTY NO. STATE SIGNATURE B. N. Nylan DATE ISSUED 01/05/89 NORTH GRID 523 000 EAST GRID 0809 000				
APPROXIMATE DEPTH OF WELL 300 FEET APPROXIMATE DIAMETER OF WELL 6 INCH METHOD OF DRILLING (circle one) ☒ BORED (or Augered) ☐ JETTED ☐ Jetted & DRIVEN ☒ AIR-ROTARY ☐ AIR-PERCussion ☐ ROTARY (Hydraulic Rotary) ☐ CABLE ☐ REVERSE-ROTARY ☐ Drive-POINT other _____				
REPLACEMENT OR DEEPEMED WELLS (CIRCLE APPROPRIATE BOX) ☒ THIS WELL WILL NOT REPLACE AN EXISTING WELL ☐ THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED ☐ THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY ☐ THIS WELL WILL DEEPEAN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPEMED (IF AVAILABLE) _____				
Not to be filled in by driller (OEP USE ONLY) APPROP. PERMIT NUMBER GAP FORCE 10-38-0037 WRITE INITIALS IN BOX SPECIAL CONDITIONS				
DIRECTION OF WELL FROM TOWN (CIRCLE BOX) ON WHICH SIDE OF ROAD (CIRCLE APPROPRIATE BOX) NORTH ☐ WEST ☐ EAST ☐ SOUTH DISTANCE FROM ROAD 530 ENTER FT. or MI FT				
SHOW MAJOR FEATURES OF BOX & LOCATE WELL WITH AN X SOURCES OF DRILLING WATER 1. well 2. _____ 3. _____ WRITE THE BOX NUMBER FROM THE MAP HERE E 806 9 N 526 3 000 000 DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEAREST ROAD JUNCTION 				

9/21/88

- (1) Grout already started &
2 dry holes filled with cement
- (2) Not sure of Location in field
near woods
- (3) 55 ft pipe
- (4) 35 ft open
- (5) 12 bags
- (6) 3 bags for each dry hole
- (7) Get information from Johnny
B. Hodges

c1 9579		SEQUENCE NO. (DENV USE ONLY)		STATE OF MARYLAND WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY PLEASE PRINT OR TYPE				THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.			
(THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)								COUNTY NUMBER			
DATE Received		DATE WELL COMPLETED		Depth of Well				PERMIT NO.			
8 13		15 20		22 26				28 29 30 31 32 33 34 35 36 37			
OWNER		last name		first name		TOWN		FROM "PERMIT TO DRILL WELL"			
STREET OR RFD		SUBDIVISION		SECTION		LOT					
WELL LOG Not required for driven wells		GROUTING RECORD		PUMPING TEST							
STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING		WELL HAS BEEN GROUTED (Circle Appropriate Box)		HOURS PUMPED (nearest hour)							
DESCRIPTION (Use additional sheets if needed)		TYPE OF GROUTING MATERIAL		PUMP RATE (gal. per min. to nearest gal.)							
FEET		CEMENT		BENTONITE CLAY		METHOD USED TO MEASURE PUMPING RATE					
FROM TO		NO. OF BAGS		NO. OF POUNDS		WATER LEVEL (distance from land surface)					
Check if water bearing		GALLONS OF WATER		DEPTH OF GROUT SEAL (to nearest foot)		BEFORE PUMPING					
		DEPTH OF GROUT SEAL (to nearest foot)		from ft. to ft.		WHEN PUMPING					
		casing types insert appropriate code below		STEEL		CONCRETE					
		MAIN		Nominal diameter		Total depth					
		CASING		top (main) casing		of main casing					
		TYPE		(nearest inch)		(nearest foot)					
		OTHER CASING (if used)		diameter		depth (feet)					
		EACH CASING		inch		from to					
		screen type or open hole		STEEL		BRASS		OPEN			
		insert appropriate code below		BRONZE		HOLE		CAPACITY:			
		C2		PLASTIC		OTHER		GALLONS PER MINUTE			
		DEPTH (nearest ft.)		PUMP HORSE POWER				PUMP COLUMN LENGTH			
		1 2		PUMP COLUMN LENGTH				CASING HEIGHT (circle appropriate box and enter casing height)			
		3 4		PUMP COLUMN LENGTH				LAND SURFACE			
		5 6		PUMP COLUMN LENGTH				(nearest foot)			
		7 8		PUMP COLUMN LENGTH				LOCATION OF WELL ON LOT			
		9 10		PUMP COLUMN LENGTH				SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND/OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)			
		11 12		PUMP COLUMN LENGTH							
		13 14		PUMP COLUMN LENGTH							
		15 16		PUMP COLUMN LENGTH							
		17 18		PUMP COLUMN LENGTH							
		19 20		PUMP COLUMN LENGTH							
		21 22		PUMP COLUMN LENGTH							
		23 24		PUMP COLUMN LENGTH							
		25 26		PUMP COLUMN LENGTH							
		27 28		PUMP COLUMN LENGTH							
		29 30		PUMP COLUMN LENGTH							
		31 32		PUMP COLUMN LENGTH							
		33 34		PUMP COLUMN LENGTH							
		35 36		PUMP COLUMN LENGTH							
		37 38		PUMP COLUMN LENGTH							
		39 40		PUMP COLUMN LENGTH							
		41 42		PUMP COLUMN LENGTH							
		43 44		PUMP COLUMN LENGTH							
		45 46		PUMP COLUMN LENGTH							
		47 48		PUMP COLUMN LENGTH							
		49 50		PUMP COLUMN LENGTH							
		51 52		PUMP COLUMN LENGTH							
		53 54		PUMP COLUMN LENGTH							
		55 56		PUMP COLUMN LENGTH							
		57 58		PUMP COLUMN LENGTH							
		59 60		PUMP COLUMN LENGTH							
		61 62		PUMP COLUMN LENGTH							
		63 64		PUMP COLUMN LENGTH							
		65 66		PUMP COLUMN LENGTH							
		67 68		PUMP COLUMN LENGTH							
		69 70		PUMP COLUMN LENGTH							
		71 72		PUMP COLUMN LENGTH							
		73 74		PUMP COLUMN LENGTH							
		75 76		PUMP COLUMN LENGTH							
		77 78		PUMP COLUMN LENGTH							
		79 80		PUMP COLUMN LENGTH							
		81 82		PUMP COLUMN LENGTH							
		83 84		PUMP COLUMN LENGTH							
		85 86		PUMP COLUMN LENGTH							
		87									

Page 7 of 21
Date 8/21/88

Review OK 8/25/88 CW

FIELD DATA SHEET
HOWARD COUNTY WELL YIELD TEST

Well Permit No. HO - 88-0039

Location of property (road) TRIADOLPHIA RD.

Subdivision TRIADOLPHIA RIDGE EST

Lot 13

Block

Plat

Sec.

Well Driller JOSEPH MAYNE

Owner

BOB RAO

Depth of well 400'

Distance of measuring point (M.P.) above ground 1'

Static water level (S.W.L.) below M.P. 22'

I. High rate pumping -- reservoir drawdown

Time pump started 7:30

Pumping rate 15 gpm.

Total time 5 min. to reach pumping water level 277 ft. below M.P.

II. Recovery pump test data - observations to be recorded every 15 minutes

TIME (in 15 minute intervals)	WATER LEVEL below M.P.	PUMPING RATE time to fill 5 gallon bucket	FLOW METER READING (if used)	CALCULATED FLOW (gallons per minute)
7:45	152'	4 sec.		15 gpm.
8:00	280	4		15 gpm.
8:15	277	60		1
8:30	277	60		1
8:45	277	60		1
9:00	277	60		1
9:15	277	60		1
9:30	277	60		1
9:45	277	60		1
10:00	277	60		1
10:15	276	60		1
10:30	276	60		1
10:45	276	60		1
11:00	276	60		1
11:15	276	60		1
11:30	276	60		1
11:45	276	60		1
12:00	276	60		1
12:15	276	60		1
12:30	276	60		1
12:45	276	60		1
1:00	276	60		1
1:15	276	60		1
1:30	276	60		1
HD-224/45	276	60		1
2:00	276	60		1

4/25/89 A.M. ✓
P.M. ✓

4/25/89 Partial A.M. not ready
P.M.

HOWARD COUNTY HEALTH DEPARTMENT
Bureau of Environmental Health
3525-H Ellicott Mills Drive
Ellicott City, MD 21043
461-9933

APPLICATION FOR PITLESS ADAPTER, WELL PUMP AND PRESSURE TANK INSTALLATION

New Installation ☒
Replacement ☐

Receipt # 43684
Date 3/1/89

Name of Installer ISAAC ALLEN NEWTON III

Telephone 301-678-6969

License Number 9025

Certified Well Pump Installer ☐ Well Driller ☐ Registered Plumber ☒

Name of Property Owner _____

Telephone _____

Subdivision W. FRIENDSHIP Lot # 13

Well Tag # 40-88-0039

Site Address 13060 TRI DRAPHIA RD.

Pump

1. Type

- a. Deep well jet ☐
b. Shallow well jet ☐
c. Submersible ☒

Motor

1. Horsepower _____
2. RPM _____
3. Voltage _____
a. 110 _____
b. 220 _____

Pitless Adapter

1. Make _____
2. Model # _____
3. Depth _____

2. Make _____

3. Model # _____

4. Capacity _____ GPM

5. Pump exceeds well capacity Yes _____ No _____

6. If Yes, is low pressure cutoff switch installed? Yes _____ No _____

7. What methods are used to protect the pump and electrical wiring from vibrations? Torque arrestors _____ Cable guards _____ Other _____

Tank

1. Capacity _____
2. Pressure relief valve? _____

Piping

1. Type _____
2. Size _____
3. NSF and/or BOCA Code approved _____
4. Depth of supply line _____

Well data

1. Depth _____ ft.
2. Yield _____ GPM
3. Static water level _____ ft.
4. Will water supply be disinfected by installer? _____

I understand that it is my responsibility to notify the Howard County Health Department when the installation is ready for inspection (otherwise this permit is null and void).

All information given above is true to the best of my knowledge.

Signature of Applicant: Isaac Allen Newton III

Date: 3-1-89

Note: A sticker indicating approval/status of the installation will be placed on the well casing at the time of the inspection. NOT SEEN PUMP OR TANK. C.B.D.

HD-215

4/25/89 Partial
Pitless adapter and line from water well to home ok for covering - only C.B.D.
NOTE: 1/25 =


known as: LOT 13

THIS PLAT CAN NOT BE USED TO ESTABLISH PROPERTY LINES OR CORNERS.



TRIADELPHIA RIDGE ESTATES
PRESUB. of LOTZ, BURGESS
PROPERTY, PLAT # 4195"
PLAT NO# 7899
3-- ELECTION DISTRICT
HOWARD COUNTY, M.D.

BP (~~Not Yet~~) B00123976
13060 Triadelphia Rd
Triadelphia Ridge Estates lot 13
(A38710)

In Ground Pool
No conflict with well
or Septic. basement
approval: R/P 5/4/00



18x40 Pool w/fence



TRIADELPHIA ROAD

LOCATION SURVEY PLAT
SUBJECT PROPERTY NOT LOCATED IN A FLOOD PLAIN AREA UNLESS OTHERWISE NOTED

Larry Matz
13060 Triadelphia Rd., Ellicott City 21042