03-312860

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH*

P 46385

A 37491

DISTRICT

DATE 9/20/90

DATE SYSTEM APPROVED 9/26/90

INSPECTOR McGee

HOWARD COUNTY
BUREAU OF ENVIRONMENTAL HEALTH
461-9933

UNDEXED

B W C, Inc. IS PERMITTED TO INSTALL X ALTER

ADDRESS 11974 Route 216, Fulton, Maryland PHONE

SUBDIVISION Triadelphia Woods ROAD 12614 Fawn Run Court LOT 44

PROPERTY OWNER T. J. Tabalis

ADDRESS

[redacted]

[redacted]

169
5(728)
195 ft trench

SEPTIC TANK CAPACITY 1250 GALLONS NUMBER OF BEDROOMS 4

TRENCHES - 180 sq. ft. per bedroom. Trench to be 2 feet wide. Inlet 3 feet below original grade. Bottom maximum depth 8 feet below original grade. Effective area begins at 3 feet below original grade. 5 feet of stone below distribution pipe.

LOCATION - Place the distribution box at a point 160 feet off the rear (235') lot line and 160' off the left (337.76') lot line as seen when facing property from Fawn Run Court. Run trenches on contour towards the left (337.76') and rear right corner of lot.

NOTE - Maintain minimum 100' from well to septic. No trench to exceed 100' in length. Provide 6" - 8" diameter cleanout and cap to grade or above on septic tank. 5-18-90 JGB

PLANS APPROVED BY Bert Nixon cm DATE 05/23/88

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCHES ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCHES!

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER. NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 8 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA OR PVC OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET, MANHOLE TO GRADE REQUIRED

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

FINAL PERMIT SIGNOFF
AND RETURNED 4/18/92
Serial # 42909 - deck

***INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT**

*CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEMS.

HD-260